


ADDENDUM TO INFORMAL BID DOCUMENTS

 SOLANO COMMUNITY COLLEGE	ADDENDUM #01
	Project: Solano Community College District Smart Classroom Upgrade Informal Bid #20-004
	Date Issued: December 3, 2019

Addendum # 01 – The following clarifications are provided based on questions received and must be added/considered when completing your submittal: Acknowledgement of receipt of this **ADDENDUM** is required on the proposal’s revised Bid Form. Please clearly note the addendum number and initial in the designated area on Revised Bid Form, Section 1.1.

ITEM:

Inquiry 1 – Confirm that shielded cable should be included on quote for 70 classrooms as it is not listed on page 14 cabling requirements item for unit pricing. Also not on list are 12-port faceplates, lollipop connectors, cat6 jacks or patch cables. Please confirm what will be required by contractor and what will be provided by district.

ITEM NO. 1 – Revision to Bid Form

This is to confirm that the shielded cable should be included on the quote as indicated on the revised Bid Form which is hereby attached and shall replace the Bid Form on page 14 in its entirety. The revised Bid Form shall include in the unit price section all cabling requirements required by the contractor. Acknowledgment of this addendum shall be noted on Section 1.1 of the revised Bid Form.

Inquiry 2 – Please confirm/clarify item on page 9 under “cabling” regarding relocate of data drop from teacher cabinet to projector. The literature addresses terminating the cable at projector end in a surface mount box, however, nothing notes where or how to terminate at the teacher station. If additional parts are required please provide part info so this can be included in bid package.

ITEM NO. 2 – Revision to Cabling, Page 9

Cabling section, page 9 included in original Request for Informal Bid, shall be revised with the following scope of work:

Relocate one (1) data drop from the existing Audio/Video Cabinet to Projector. An RJ-45 Modular Plug to be crimped onto the cable at A/V cabinet location.

A new Cat 6 cable, also to have an RJ-45 modular plug crimped onto the end, to be run from the A/V cabinet location wall plate to the projector and terminated into the 2 port surface mounted box (sharing with the Shielded CAT 6 running from A/V cabinet location).

The new cable will then be connected to the relocated data drop via a Cat 6 RJ-45 Coupler. The coupler location will be placed/located behind the wall plate at the AV cabinet location.

Any modifications, revisions or changes made by this addendum affect only the portions or paragraphs specifically identified herein; all remaining portions of the RIFB document, terms and conditions of RIFB #20-004, Smart Classroom Upgrade, Solano Community College is to remain the same and remain in force. It is the responsibility of all bidders to conform to this addendum.

Addendum No. 1
Revision to Bid Form

Bid Form

Bidder Name: _____

Unit Pricing

Note: Unit Pricing will not be used to determine lowest bidder. Lowest bidder will be determined by the total bid proposal amount filled in Section 1.1 below.

Description	Unit Price
Cablings Requirements:	
1. Cat 6 Cable Plenum LANmark6 FTP White – Berk-Tek or Equal	\$
2. Cat 6 Cable Plenum LANmark6 FTP White (Shielded) – Berk-Tek or Equal	\$
3. #16/2 Red and White Plenum Speaker Wire – Belden or Equal	\$
4. 12 Port faceplate with ID Window Ivory – Leviton or Equal	\$
5. Cat 6 Shielded Jack Blue – Leviton or Equal	\$
6. Audio RCA Connector Red Stripe Ivory – Leviton or Equal	\$
7. Audio RCA Connector Black Stripe Ivory – Leviton or Equal	\$
8. 2 Port Surface Mount Box Ivory – Leviton or Equal	\$
9. Caddy Mounting Bracket, 1-Gang – Caddy (nVent) or Equal	\$
10. Quickport Blank Insert Ivory (10 pack) – Leviton or Equal	\$
11. Lollipop Speaker Wire Cable – Lollipop or Equal	\$
12. Cat 6 Jack – Leviton or Equal	\$
13. Cat 6 RJ-45 Modular Plug (Connector) – Leviton or Equal	\$
14. Cat 6 RJ-45 Coupler – Leviton or Equal	\$
If pricing alternate, then list equivalent (attach additional sheet if necessary):	
1.	
2.	
3.	

Bid Proposal

Lump Sum, Not to Exceed to perform the Contract	\$
Owner's Non-Specified Allowance	\$ 1, 200.00
Total Bid Proposal Amount to be filled in Section 1.1 below.	\$

1.1 Bid Proposal Amount. The undersigned Bidder proposes and agrees to perform the Contract including, without limitation, providing and furnishing any and all of the labor, materials, tools, equipment and services necessary to perform the Contract and complete in a workmanlike manner all of the Work required for the Project described as: **RIFB 20-004 Smart Classroom Upgrade Project, Solano Community College District** for the sum of _____ Dollars (\$_____) which includes the Owner's Non-Specified Allowance of \$1,200.00. The Bidder confirms that it has checked all of the above figures and understands that neither the District nor any of its agents, employees or representatives shall be responsible for any errors or omissions on the part of the undersigned Bidder in preparing and submitting this Bid Proposal.

1.1 Acknowledgment of Bid Addenda. The Bidder confirms that this Bid Proposal incorporates and is inclusive of, all items or other matters contained in Bid Addenda issued by or on behalf of the District.

_____ **Addenda Nos.** _____ received, acknowledged
(initial) and incorporated into this Bid Proposal.