


ADDENDUM TO RFP DOCUMENTS

 <p>SOLANO COMMUNITY COLLEGE</p>	ADDENDUM #01
	Project: Solano Community College District Building Automation System (BAS) Retrofit Phase 2 Project
	Date: October 29, 2018

The following clarifications are provided based on questions received or changes in District requirements and must be added/considered when completing your submittal: Acknowledgement of receipt of this **ADDENDUM** is required in the proposal's cover letter of introduction. Please clearly note the addendum date and number.

ITEM:

ITEM NO. 1 – CLARIFICATION OF PRE-PROPOSAL MEETING TIME

Revision to pre-proposal meeting time provided on page 7 of Request for Qualifications/Request for Proposals. **Pre-proposal meeting time will be 10:00am**, in lieu of 9:00am as stated on page 7 of Request for Qualifications/Request for Proposals.

ITEM NO. 2 – ANSWERS TO SUBMITTED QUESTIONS

QUESTION – *What is the Controls System spec'd out for this project?*

ANSWER – *The remaining buildings, currently on an Alerton System, will need to be converted to Delta Controls and integrated into the existing campus wide Delta Controls management system.*